

# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Govt. of Haryana Undertaking)

## Clarification No. 1

NIT No: TER-21 /R-APDRP/2016

Firm's Points	Nigam's Clarification
<p>While quoting the reference of the subject cited tender enquiry, it is mentioned that only one fire suppression agent – Novec-1230 is specified and this puts other fire suppression agent (FM-200) at disadvantage and out of bidding though both agents are approved by NFPA 2001 and only FM-200 has been recommended by Ministry of Environment and Forest, Govt. of India.</p>	<p>The fire suppression system shall be supplied as per the detail mentioned under Clause 1.6.1 of section: 9 (Technical Specifications) of tender document.</p>

All other terms and conditions of the tender shall remain same.

*Ans*  
6/4/16

**SE/R-APDRP,  
For CE/R-APDRP, DHBVN, Hisar.**

"You can pay your electricity bill online at [www.dhbvn.org.in](http://www.dhbvn.org.in)"